

Part No. M210076
 4 gang masonry box 2-1/2" d x 3-3/4" h
 Typical: Raco #693 or Crouse Hinds Tp685
 (mounting by others)

Ceiling

Top or End Canopy Mount

AC Power Connection

Power Supply Mounted to Canopy

Low Voltage 5VDC connection to REMOTE UNIT (if required)

Maximum run of 2 conductor wiring (by others):
 50 ft. = AWG 22
 100 ft. = AWG 18

4X No. 6 screws Attaches Canopy to Masonry Box

Single or Double Face Sign

Test Switch and Status Indicator EM Models only

Additional holes to secure Back Plate to wall

Wall

Back Plate

Wall Mount

Power Supply Mounted to Back Plate

AC Power Connection

4x Set Screws (tighten on mounting pins while holding UNIT flush to wall)

Mounting Pins (insert into holes of Razor Exit Sign)

4X No. 6 screws Attaches Back Plate to Masonry Box

Low Voltage 5VDC connection to REMOTE UNIT (if required)

RAZOR RZR EXIT SIGN INSTALLATION DRAWING



EMERGENCY LIGHTING
 EXIT & SAFETY SIGNS

3161 STATE ROAD
 BENSALEM, PA 19020