


MODEL TCVS INSTALLATION INSTRUCTIONS FOR WET LOCATION ENCLOSURE

IMPORTANT: DISCONNECT POWER BEFORE INSTALLATION



Warnings and Cautions

IMPORTANT SAFEGUARDS


READ AND FOLLOW ALL SAFETY INSTRUCTIONS

1. Review the diagrams thoroughly before beginning. Please have your fixture installed by a qualified licensed electrician.
2. All electrical connections must be in accordance with local codes, ordinances, and the National Electric Code.
3. Before starting the installation, disconnect the power by turning off the circuit breaker or by removing the appropriate fuse at the fuse box. Turning the power off using the light switch is not sufficient to prevent electrical shock.
4. Do not mount near gas or electric heaters.
5. Use cautions when servicing batteries. Battery acid can cause burns to skin and eyes. If acid is spilled on skin or in eyes, flush acid with fresh water and contact a physician immediately.
6. Equipment should be mounted in location and at heights where it will not readily be subject to tampering by unauthorized personnel.
7. The use of accessory equipment not recommend by the manufacturer may cause an unsafe condition.
8. Do not use this equipment for other than intended use.
9. All servicing should be performed by qualified personnel only.
10. Installer is responsible to ensure the watertight integrity of the enclosure.


Mounting Instructions

NOTE: First turn off electricity.


1. Disassemble clear cover.




2. Knock out or drill mounting holes as required




3. Install mounting plate to J-box.



4. Secure emergency lighting fixture back plate to waterproof case back plate, then install the fixture.
(Reference emergency light instruction sheet)



5. After install emergency lighting, Assemble clear cover by screw.
Notice silicone test button on bottom side.



6. Push silicone test button, lamp head will turn on, finish installation.

